

This information was last updated on 12 December 2023, is current as of that date and replaces all previous versions

GAS SPECIFICATIONS AND PRESSURE REQUIREMENTS

The following is for indicative information only. The applicable specification is included in each gas transportation agreement, connection agreement or other agreement between Darling Downs Pipeline and its counterparties.

| Component | Units | Min | Max |
|----------------------------------|--------------------|-----------|-----------|
| N ₂ | mol% | 0.00 | 3.50 |
| CO ₂ | mol% | 0.00 | 1.50 |
| Total Inert Gases | mol% | 0.00 | 5.00 |
| C1 (Methane) | mol% | 94.00 | 100.00 |
| C2 (Ethane) | mol% | 0.00 | 0.15 |
| C ₃₊ (Propanes +) | mol% | 0.00 | 0.00 |
| H ₂ S | ppmv | 0.00 | 4.00 |
| Total Mercaptan Sulfur | ppmv | 0.00 | 1.00 |
| Carbonyl Sulphide | ppmv | 0.00 | 2.00 |
| Total Sulfur | mg/Sm ³ | 0.00 | 20.00 |
| Water Dew Point @ 13.5MPag | deg C | - | 0.00 |
| Hydrocarbon Dew Point @ 3.5 MPag | deg C | - | 2.00 |
| Oxygen | ppmv | 0.00 | 10.00 |
| Water | mg/Sm ³ | 0.00 | 65.00 |
| Mercury | µg/Sm ³ | 0.00 | 20.00 |
| Triethylene Glycol | | Saturated | Saturated |
| BTEX | ppmv | 0.00 | 4.00 |

Other: Reasonably free from dust, gum forming constituents, other liquids or solids. Reasonably free of unsaturated or aromatic hydrocarbons. Free of other substances that may cause damage to equipment or may form products that are hazardous to health.

| Connection Point | Minimum Pressure (kPa) | Maximum Pressure (kPa) |
|------------------|------------------------|------------------------|
| DDP134 | 13,800 | 14,500 |
| | | |